

LK	Benzen	µg/l	(A) PN-ISO 11423-1:2002	MZ-2 1,0	< 0,50		
LK	Benzo(a)piren	µg/l	(A) PB-160/LF wyd. 6 z dnia 15.03.2016	MZ-2 0,010	< 0,0020		
LK	beta-HCH	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LK	Bor	mg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 1,0	0,022		±0,002
LK	Bromiany	µg/l	(A) PN-EN ISO 15061:2003	MZ-2 10	< 2,0		
LK	Chlorki	mg/l	(A) PN-EN ISO 10304-1:2009	MZ-2 250	20		±3
LK	Chrom	µg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 50	< 3,0		
LK	Cyjanki ogólne	µg/l	(A) PN-EN ISO 14403-2:2012	MZ-2 50	< 10		
LK	delta-HCH	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LK	Dieldryna	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,030	< 0,010		
LK	Endryna	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LK	Epoksyd heptachloru B	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,030	< 0,010		
LK	Fluorki	mg/l	(A) PN-EN ISO 10304-1:2009	MZ-2 1,5	0,13		±0,03
LK	gamma-HCH, lindan	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LK	Glin/aluminium	µg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 200	< 10		