

LK	Heksachlorocykloheksan (HCH)	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,100	< 0,010		
LK	Heptachlor	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,030	< 0,010		
LK	Indeks nadmanganianowy (utlenialność)	mg/l	(A) PN-EN ISO 8467:2001	MZ-2 5,0	2,2		±0,4
LK	Izodryna	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LK	Jon amonowy	mg/l	(A) PN-EN ISO 11732:2007	MZ-2 0,50	< 0,13		
LK	Kadm	µg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 5	< 0,5		
LK	Mangan	µg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 50	< 1,0		
LK	Miedź	mg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 2,0	< 0,004		
LK	Nikiel	µg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 20	< 4,0		
LK	o,p'-DDT	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LK	Ołów	µg/l	(Ae) PN-EN ISO 11885:2009	MZ-2 10	< 4,0		
LK	p,p'-DDT	µg/l	(Ae) PN-EN ISO 6468:2002	MZ-2 0,10	< 0,010		
LŁ	pH	-	(A) PN-EN ISO 10523:2012	MZ-2 6,5 - 9,5	7,4		±0,2
LŁ	Przewodność elektryczna właściwa	µS/cm	(A) PN-EN 27888:1999 (korekta urzędzeniem do kompensacji wpływu temp.)	MZ-2 2500	567		±28
LK	Rtęć	µg/l	(Ae) PN-EN 1483:2007	MZ-2 1	< 0,10		